

**EMSL ANALYTICAL INC.  
200 ROUTE 130 NORTH  
CINNAMINSON, NJ 08077**

**POTABLE WATER RESULTS**

**CERTIFICATE OF ANALYSIS**

**012517593**

**NJ ELKS ELEMENTARY SCHOOL  
1481 MAIN AVENUE  
CLIFTON, NJ**

**MAY 5, 2025**

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:cs@emsl.com  
EMSL-CIN-01

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

May 05, 2025

Scott Higgins  
ABS Environmental Group, LLC [ABSG36]  
PO Box 483  
Glenwood, NJ 07418

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/21/2025. The results are tabulated on the attached pages for the following client designated project:

**NJ Elks School-1481 Main St, Clifton, NJ**

The reference number for these samples is EMSL Order #: AD17593 . Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact the lab at 856-858-4800.

A handwritten signature in black ink, appearing to read 'Owen McKenna'.

---

Owen McKenna Laboratory Manager or other approved signatory

## Table of Contents

Cover Letter	1
Sample Condition on Receipt	3
Samples in Report	4
Positive Hits Summary	5
Sample Results	7
Quality Assurance Results	33
Certified Analyses	35
Certifications	35
Qualifiers, Definitions and Disclaimer	36
Chain of Custody PDF	37



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Condition on Receipt**

Cooler ID: Default Cooler	Temperature: °C
Custody Seals	N
Containers Intact	N
COC/Labels Agree	N
Preservation Confirmed	N

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins

ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 ahsenv@warwick.net

**Project Name:**

NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:****EMSL Sales Rep:**

Justin Monturano

**Received:**

04/21/2025 09:00

**Reported:**

05/05/2025 18:00

**EMSL Order ID:** 012517593**LIMS Reference ID:** AD17593**EMSL Customer ID:** ABSG36**Samples in this Report**

Lab ID	Sample	Matrix	Date Sampled	Date Received
AD17593-01	ABS-01-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-02	ABS-02-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-03	ABS-03-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-04	ABS-04-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-05	ABS-05-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-06	ABS-06-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-07	ABS-07-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-08	ABS-08-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-09	ABS-09-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-10	ABS-10-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-11	ABS-11-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-12	ABS-12-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-13	ABS-13-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-14	ABS-14-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-15	ABS-15-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-16	ABS-16-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-17	ABS-17-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-18	ABS-18-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-19	ABS-19-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-20	ABS-20-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-21	ABS-21-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-22	ABS-22-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-23	ABS-23-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-24	ABS-24-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-25	ABS-25-2	Drinking Water	4/18/25 10:00 am	04/21/2025
AD17593-26	ABS-26-2	Drinking Water	4/18/25 10:00 am	04/21/2025



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Positive Hits Summary**

Lab ID	Client ID					Sampled
AD17593-03	ABS-03-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	37		µg/L	04/30/2025 18:12	
AD17593-08	ABS-08-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	71		µg/L	04/30/2025 18:28	
AD17593-09	ABS-09-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	53		µg/L	04/30/2025 18:31	
AD17593-10	ABS-10-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	380		µg/L	04/30/2025 18:33	
EPA 200.8	Lead	52.3		µg/L	04/30/2025 18:33	
AD17593-11	ABS-11-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	110		µg/L	04/30/2025 18:35	
EPA 200.8	Lead	7.61		µg/L	04/30/2025 18:35	
AD17593-14	ABS-14-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	48		µg/L	04/30/2025 18:51	
AD17593-19	ABS-19-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	41		µg/L	04/30/2025 19:03	

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Positive Hits Summary**  
 (Continued)

Lab ID	Client ID					Sampled
AD17593-23	ABS-23-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	47		µg/L	04/30/2025 16:44	
Lab ID	Client ID					Sampled
AD17593-24	ABS-24-2					04/18/25 10:00
Method	Analyte	Result	Qualifier	Unit	Analyzed	
EPA 200.8	Copper	38		µg/L	04/30/2025 16:46	

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**

**Sample: ABS-01-2**  
**AD17593-01 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:03	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:03	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano

**Received:** 04/21/2025 09:00

**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample:** ABS-02-2  
 AD17593-02 (Drinking Water)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:10	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:10	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-03-2**  
**AD17593-03 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	37		1	35	µg/L	04/28/25 17:13	04/30/25 18:12	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:12	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-04-2**  
**AD17593-04 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:14	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:14	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano

**Received:** 04/21/2025 09:00

**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-05-2**  
**AD17593-05 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:17	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:17	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins

ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:**

NJ Eiks School-1481 Main St, Clifton, NJ

**Customer PO:****EMSL Sales Rep:**

Justin Monturano

**Received:**

04/21/2025 09:00

**Reported:**

05/05/2025 18:00

**Sample Results**

(Continued)

**Sample:** ABS-06-2

AD17593-06 (Drinking Water)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:24	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:24	MEK/JW1	EPA 200.8 (DA)	EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-07-2**  
**AD17593-07 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:26	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:26	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-08-2**  
**AD17593-08 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	71		1	35	µg/L	04/28/25 17:13	04/30/25 18:28	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:28	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-09-2**  
**AD17593-09 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	53		1	35	µg/L	04/28/25 17:13	04/30/25 18:31	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:31	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-10-2**  
**AD17593-10 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	380		1	35	µg/L	04/28/25 17:13	04/30/25 18:33	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	52.3		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:33	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax: cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-11-2**  
**AD17593-11 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	110		1	35	µg/L	04/28/25 17:13	04/30/25 18:35	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	7.61		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:35	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins

ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:**

NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:****EMSL Sales Rep:**

Justin Monturano

**Received:**

04/21/2025 09:00

**Reported:**

05/05/2025 18:00

**Sample Results**

(Continued)

**Sample:** ABS-12-2

AD17593-12 (Drinking Water)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:42	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:42	MEK/JW1	EPA 200.8 (DA)	EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample:** ABS-13-2  
 AD17593-13 (Drinking Water)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:44	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:44	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-14-2**  
**AD17593-14 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	48		1	35	µg/L	04/28/25 17:13	04/30/25 18:51	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:51	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-15-2**  
**AD17593-15 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:53	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:53	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-16-2**  
**AD17593-16 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:56	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:56	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax: cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**EMSL Order ID:** 012517593**LIMS Reference ID:** AD17593**EMSL Customer ID:** ABSG36**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ**Customer PO:****EMSL Sales Rep:** Justin Monturano**Received:** 04/21/2025 09:00**Reported:** 05/05/2025 18:00**Sample Results**

(Continued)

**Sample: ABS-17-2**  
**AD17593-17 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 18:58	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 18:58	MEK/JW1	EPA 200.8 (DA)	EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-18-2**  
**AD17593-18 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 19:00	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 19:00	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**  
 200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-19-2**  
**AD17593-19 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	41		1	35	µg/L	04/28/25 17:13	04/30/25 19:03	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 19:03	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-20-2**  
**AD17593-20 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/28/25 17:13	04/30/25 19:05	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/28/25 17:13	04/30/25 19:05	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-21-2**  
**AD17593-21 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/30/25 13:15	04/30/25 16:35	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/30/25 13:15	04/30/25 16:35	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample:** ABS-22-2  
 AD17593-22 (Drinking Water)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/30/25 13:15	04/30/25 16:42	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/30/25 13:15	04/30/25 16:42	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**  
 200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-23-2**  
**AD17593-23 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	47		1	35	µg/L	04/30/25 13:15	04/30/25 16:44	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/30/25 13:15	04/30/25 16:44	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-24-2**  
**AD17593-24 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	38		1	35	µg/L	04/30/25 13:15	04/30/25 16:46	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/30/25 13:15	04/30/25 16:46	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-25-2**  
**AD17593-25 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/30/25 13:15	04/30/25 16:49	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/30/25 13:15	04/30/25 16:49	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Sample Results**  
 (Continued)

**Sample: ABS-26-2**  
**AD17593-26 (Drinking Water)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Prep/Analyst Initials	Prep Method	Analytical Method
<b>Metals</b>										
Copper	ND		1	35	µg/L	04/30/25 13:15	04/30/25 16:55	MEK/JW1	EPA 200.8 (DA)	EPA 200.8
Lead	ND		1	1.00	µg/L	04/30/25 13:15	04/30/25 16:55	MEK/JW1	EPA 200.8 (DA)	EPA 200.8

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**  
 200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-D1

**EMSL Order ID:** 012517593  
**LIMS Reference ID:** AD17593  
**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ  
**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

### Quality Control

#### Metals

Analyte	Result/Qual	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<b>Batch: BDD2959 - EPA 200.8 (DA)</b>									
<b>Blank (BDD2959-BLK1)</b>									
				Prepared: 4/28/2025 Analyzed: 4/30/2025					
Copper	ND	35	µg/L						
Lead	ND	1.00	µg/L						
<b>LCS (BDD2959-BS1)</b>									
				Prepared: 4/28/2025 Analyzed: 4/30/2025					
Copper	246	35	µg/L	250.0		98	85-115		
Lead	10.2	1.00	µg/L	10.00		102	85-115		
<b>LCS Dup (BDD2959-BSD1)</b>									
				Prepared: 4/28/2025 Analyzed: 4/30/2025					
Copper	252	35	µg/L	250.0		101	85-115	3	20
Lead	9.99	1.00	µg/L	10.00		100	85-115	2	200
<b>Matrix Spike (BDD2959-MS1)</b>									
				Source: AD17593-01		Prepared: 4/28/2025 Analyzed: 4/30/2025			
Copper	271	35	µg/L	250.0	33.8	95	70-130		
Lead	11.1	1.00	µg/L	10.00	0.456	106	70-130		
<b>Matrix Spike (BDD2959-MS2)</b>									
				Source: AD17593-11		Prepared: 4/28/2025 Analyzed: 4/30/2025			
Copper	340	35	µg/L	250.0	113	91	70-130		
Lead	18.0	1.00	µg/L	10.00	7.61	104	70-130		
<b>Matrix Spike Dup (BDD2959-MSD1)</b>									
				Source: AD17593-01		Prepared: 4/28/2025 Analyzed: 4/30/2025			
Copper	265	35	µg/L	250.0	33.8	93	70-130	2	20
Lead	11.0	1.00	µg/L	10.00	0.456	106	70-130	0.3	20
<b>Matrix Spike Dup (BDD2959-MSD2)</b>									
				Source: AD17593-11		Prepared: 4/28/2025 Analyzed: 4/30/2025			
Copper	340	35	µg/L	250.0	113	91	70-130	0.2	20
Lead	18.1	1.00	µg/L	10.00	7.61	105	70-130	0.5	20

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.


**EMSL Analytical, Inc.**

 200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax: cs@emsl.com  
 EMSL-CIN-01

**EMSL Order ID:** 012517593

**LIMS Reference ID:** AD17593

**EMSL Customer ID:** ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

**Quality Control**  
 (Continued)

**Metals (Continued)**

Analyte	Result Qual	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<b>Batch: BDD2963 - EPA 200.8 (DA)</b>									
<b>Blank (BDD2963-BLK1)</b>									
				Prepared & Analyzed: 4/30/2025					
Copper	ND	35	µg/L						
Lead	ND	1.00	µg/L						
<b>LCS (BDD2963-BS1)</b>									
				Prepared & Analyzed: 4/30/2025					
Copper	245	35	µg/L	250.0		98	85-115		
Lead	9.93	1.00	µg/L	10.00		99	85-115		
<b>LCS Dup (BDD2963-BSD1)</b>									
				Prepared & Analyzed: 4/30/2025					
Copper	248	35	µg/L	250.0		99	85-115	1	20
Lead	10.0	1.00	µg/L	10.00		100	85-115	1	200
<b>Matrix Spike (BDD2963-MS1)</b>									
				Source: AD17593-22		Prepared & Analyzed: 4/30/2025			
Copper	239	35	µg/L	250.0	ND	96	70-130		
Lead	9.78	1.00	µg/L	10.00	ND	98	70-130		
<b>Matrix Spike (BDD2963-MS2)</b>									
				Source: AD18817-01		Prepared & Analyzed: 4/30/2025			
Copper	253	35	µg/L	250.0	17.4	94	70-130		
Lead	10.6	1.00	µg/L	10.00	ND	106	70-130		
<b>Matrix Spike Dup (BDD2963-MSD1)</b>									
				Source: AD17593-22		Prepared & Analyzed: 4/30/2025			
Copper	237	35	µg/L	250.0	ND	95	70-130	0.9	20
Lead	10.1	1.00	µg/L	10.00	ND	101	70-130	3	20
<b>Matrix Spike Dup (BDD2963-MSD2)</b>									
				Source: AD18817-01		Prepared & Analyzed: 4/30/2025			
Copper	258	35	µg/L	250.0	17.4	96	70-130	2	20
Lead	10.9	1.00	µg/L	10.00	ND	109	70-130	3	20

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

**Attention:** Scott Higgins

ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:**

NJ Eiks School-1481 Main St, Clifton, NJ

**Customer PO:****EMSL Sales Rep:**

Justin Monturano

**Received:**

04/21/2025 09:00

**Reported:**

05/05/2025 18:00

**Certified Analyses included in this Report**

Analyte	CAS #	Certifications
<b>EPA 200.8 In Drinking Water</b>		
Copper	7440-50-8	NJDEP
Lead	7439-92-1	NJDEP

**List of Certifications**

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:cs@emsl.com  
 EMSL-CIN-01

EMSL Order ID: 012517593

LIMS Reference ID: AD17593

EMSL Customer ID: ABSG36

**Attention:** Scott Higgins  
 ABS Environmental Group, LLC [ABSG36]  
 PO Box 483  
 Glenwood, NJ 07418  
 (973) 583-8500  
 absenv@warwick.net

**Project Name:** NJ Elks School-1481 Main St, Clifton, NJ

**Customer PO:**  
**EMSL Sales Rep:** Justin Monturano  
**Received:** 04/21/2025 09:00  
**Reported:** 05/05/2025 18:00

### Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
{2C}	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.
%REC	Percent Recovery
RPD	Relative Percent Difference
Source	Sample that was matrix spiked or duplicated

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.